






NOTE: A = 0 FOR ALL
END SUCTION PUMPS

- INSTALL ALL DRAIN PIPING FULL SIZE TO AIR GAP OR OPEN DRAIN
- UNIT IS NOT DESIGNED TO SUPPORT PIPING.
- ALL CONNECTING PIPING MUST BE FIELD
SUPPORTED & ANCHORED.




MODEL	A	B	C
106-D	4 3/4	4	3 1/2
110-D	4 3/4	4 1/4	0
113-D	5 3/8	5 7/16	3 1/4
114-D	7	6 3/4	3 1/4
116-D	5 3/8	8 3/8	3 1/4
116-AWF	6 9/16	5 7/8	3 1/8
117-D	5 3/8	5 7/16	-9/16
121-D	5 3/8	6 11/16	-9/16
121-AW	0	6 3/4	3 3/4
127-D	5 3/8	6 11/16	3 1/4
128-D	7	3 13/16	5
129-D	7	6 3/4	5
129-AW	0	8 1/4	5
130-D	7	6 3/4	5
130-AW	0	8 1/4	5
131-D	7	6 3/4	5 3/4
132-D	8 1/2	8	6 3/8
133-AW	8 1/2	9 1/8	5 3/4



34-119gal



16-27gal



*For Mechanical Alternators and High Alarm Floats, use 8 1/2" min inlet height

REC	L	W	H	A	B	C	D	E	F	G	I	J	K	M	N
16 GAL	24	18	9	2 NPT	1 1/4 NPT	1 1/4 NPT	3/4 NPT	2	6	9	30	27 1/2	7 7/8	6 3/4	6 1/2
20 GAL	24	18	11	2 NPT	1 1/4 NPT	1 1/4 NPT	3/4 NPT	2	6	9	36	27 1/2	9 7/8	8 3/4	8 1/2
22 GAL	24	24	9	2 NPT	1 1/4 NPT	1 1/4 NPT	3/4 NPT	2	6	9	36	33 1/2	7 7/8	6 3/4	6 1/2
27 GAL	24	24	11	2 NPT	1 1/4 NPT	1 1/4 NPT	3/4 NPT	2	6	9	36	33 1/2	9 7/8	8 3/4	8 1/2
34 GAL	30	30	9	2 NPT	1 1/2 NPT	1 1/2 NPT	3/4 NPT	3	8	12	42	31 1/2	7 7/8	6 3/4	6 1/2
42 GAL	30	30	11	2 NPT	1 1/2 NPT	1 1/2 NPT	3/4 NPT	3	8	12	42	31 1/2	9 7/8	8 3/4	8 1/2
50 GAL	36	36	9	2 NPT	1 1/2 NPT	1 1/2 NPT	3/4 NPT	3	8	12	48	37 1/2	7 7/8	6 3/4	6 1/2
61 GAL	36	36	11	2 NPT	1 1/2 NPT	1 1/2 NPT	3/4 NPT	3	8	12	48	37 1/2	9 7/8	8 3/4	8 1/2
68 GAL	42	42	9	2 NPT	1 1/2 NPT	1 1/2 NPT	1 NPT	3	8 1/2	12 1/2	54	43 1/2	7 7/8	6 3/4	6 1/2
84 GAL	42	42	11	2 NPT	1 1/2 NPT	1 1/2 NPT	1 NPT	3	8 1/2	12 1/2	54	43 1/2	9 7/8	8 3/4	8 1/2
97 GAL	50	50	9	3 NPT	1 1/2 NPT	1 1/2 NPT	3/4 NPT	3	8 1/2	12 1/2	62	51 1/2	7 7/8	6 3/4	6 1/2
119 GAL	50	50	11	3 NPT	1 1/2 NPT	1 1/2 NPT	3/4 NPT	3	8 1/2	12 1/2	62	51 1/2	9 7/8	8 3/4	8 1/2

STANDARD PLATE THICKNESS - 3/16"



SHIPPENSBURG PUMP CO., INC.

P.O. Box 279 Shippensburg, PA 17257
(717) 532-7321 • www.shipcopumps.com

SHIPCO® is a registered trademark of Shippensburg Pump Co., Inc.

DURABLE STEEL MODIFIED CONDENSATE UNIT

SECTION	DRAWING NO.	REV.	DATE
DSMU	TK-DSMU-LIT	4	5/2/2025